

Report# 673

Filename 180502BFW.pdf

4240 Passmore Upper Road, Winlaw BC, V0G2J0 250-226-7339 test@passmorelaboratory.ca passmorelaboratory.ca

Client Beaver Falls Waterworks

Attention Shirley & Wendy

	CERTIFICATE OF ANALYSIS	
<u>Analyses</u>	Method Description	<u>Reference</u>
Total Coliforms	Membrane Filtration on LES Endo medium	APHA 9222B
E. coli	MF Partition on NA-MUG medium	APHA 9222I
Fecal Coliforms	Membrane Filtration on mFC medium	APHA 9222D

Tests were performed in accordance with methods outlined in the "Standard Methods for the Examination of Water and Wastewater", 23rd Edition, 2017 published by the American Public Health Association.

Passmore Laboratory Ltd. complies with methods and certification through the Province of British Columbia Enhanced Water Quality Assurance (EWQA) Program and the Clinical Microbiology Proficiency Testing (CMPT) Program. Other analytical results on this report not listed above are not within the scope of the EWQA.

Processed by: Mechelle Babic

Jennifer Yeow, Lab Manager Junifur Yeon-

Please call or Email for with any questions, feedback, or more information

May 3, 2018 Page 1 of 2



Report# 673

Filename 180502BFW.pdf

ΔΝΔ	IYTICA	I RFS	III TS

Sample Site Well 1 Sample #				
Date/Time Sampled 2018-05-02	12:10 PM Matrix	Untreateated ground	Temperature on Receipt	7
Date/Time on Test 2018-05-02	8:30 PM			
<u>Analyses</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>	
Coliforms, Total	Less than 1	CFU/100mL	1	
Verified E.coli	Less than 1	CFU/100mL	1	
Fecal (Thermotolerant) Coliforms	Less than 1	CFU/100mL	1	

Sample Site Reservoir Sample #				2
Date/Time Sampled 2018-05-02	12:00 PM Matrix	Untreated ground	Temperature on Receipt	6
Date/Time on Test 2018-05-02	8:30 PM			
<u>Analyses</u>	<u>Result</u>	<u>Units</u>	RDL	
Coliforms, Total	Less than 1	CFU/100mL	1	
Verified E.coli	Less than 1	CFU/100mL	1	
Fecal (Thermotolerant) Coliforms	Less than 1	CFU/100mL	1	

## **Glossary of Terms**

Less than the Reportable Detection Limit, except under circumstances where the detection limit is higher due to

interferences, insufficient sample volume, or dilutions

APHA American Pubic Health Association
CFU/100mL Colony Forming Units per 100 milliliters

Matrix SW = Surface water, TW = Treated water, DW= Distribution water, UGW = Untreated Ground water, RW = Raw water

RDL Reportable Detection Limit

## References

May 3, 2018 Page 2 of 2