

4240 Passmore Upper Road, Winlaw BC, V0G2J0
250-226-7339
test@passmorelaboratory.ca
passmorelaboratory.ca

Client Beaver Falls Waterworks
Attention Shirley & Wendy

CERTIFICATE OF ANALYSIS

<u>Analyses</u>	<u>Method Description</u>	<u>Reference</u>
Total Coliforms	Membrane Filtration on LES Endo medium	APHA 9222B
E. coli	MF Partition on NA-MUG medium	APHA 9222I
Fecal Coliforms	Membrane Filtration on mFC medium	APHA 9222D

Tests were performed in accordance with methods outlined in the "Standard Methods for the Examination of Water and Wastewater", 23rd Edition, 2017 published by the American Public Health Association.

Passmore Laboratory Ltd. complies with methods and certification through the Province of British Columbia Enhanced Water Quality Assurance (EWQA) Program and the Clinical Microbiology Proficiency Testing (CMPT) Program. Other analytical results on this report not listed above are not within the scope of the EWQA.

Processed by: Zach Yeow

Jennifer Yeow,
Lab Manager



Please call or Email for with any questions, feedback, or more information

ANALYTICAL RESULTS

Sample Site	Well 1			Sample #	1	
Date/Time Sampled	2018-05-01	10:00 AM	Matrix	UGW	Temperature on Receipt	7
Date/Time on Test	2018-05-01	4:20 PM				
<u>Analyses</u>		<u>Result</u>	<u>Units</u>	<u>RDL</u>		
Coliforms, Total		Less than 1	CFU/100mL	1		
Verified E.coli		Less than 1	CFU/100mL	1		
Fecal (Thermotolerant) Coliforms		Less than 1	CFU/100mL	1		

Sample Site	Reservoir			Sample #	3	
Date/Time Sampled	2018-05-01		Matrix	Well	Temperature on Receipt	6
Date/Time on Test	2018-05-01	4:20 PM				
<u>Analyses</u>		<u>Result</u>	<u>Units</u>	<u>RDL</u>		
Coliforms, Total		Less than 1	CFU/100mL	1		
Verified E.coli		Less than 1	CFU/100mL	1		
Fecal (Thermotolerant) Coliforms		Less than 1	CFU/100mL	1		

Glossary of Terms

<	Less than the Reportable Detection Limit, except under circumstances where the detection limit is higher due to interferences, insufficient sample volume, or dilutions
APHA	American Public Health Association
CFU/100mL	Colony Forming Units per 100 milliliters
Matrix	SW = Surface water, TW = Treated water, DW = Distribution water, UGW = Untreated Ground water, RW = Raw water
RDL	Reportable Detection Limit

References