

4240 Passmore Upper Road, Winlaw BC, V0G2J0 250-226-7339 test@passmorelaboratory.ca passmorelaboratory.ca

Client Beaver Falls Waterworks

Attention Shirley Fletcher & Wendy Settle

	CERTIFICATE OF ANALYSIS	
<u>Analyses</u>	Method Description	<u>Reference</u>
Total Coliforms	Membrane Filtration on LES Endo medium	APHA 9222B
E. coli	MF Partition on NA-MUG medium	APHA 9222I

Tests were performed in accordance with methods outlined in the "Standard Methods for the Examination of Water and Wastewater", 23rd Edition, 2017 published by the American Public Health Association.

Passmore Laboratory Ltd. complies with methods and certification through the Province of British Columbia Enhanced Water Quality Assurance (EWQA) Program and the Clinical Microbiology Proficiency Testing (CMPT) Program. Other analytical results on this report not listed above are not within the scope of the EWQA. Passmore Laboratory assumes no responsibility for any loss or damage resulting from error or omission in the conduct of testing. Liability is limited to the cost of the analysis.

Processed by: Lynne Alexander

Jennifer Yeow, Lab Manager

Juniper years

Please call or Email for with any questions, feedback, or more information

## Passmore Laboratory Ltd.

Report# 2257 Filename 200205BFW.pdf

## ANALYTICAL RESULTS

Sample ID Well 1				Sample #	1
Date/Time Sampled	2020-02-04	12:10 PM Matrix	UGW	Temperature on Receipt	5
Date/Time on Test	2020-02-05	12:55 PM			
<u>Analyses</u>		<u>Result</u>	<u>Units</u>	RDL	
Coliforms, Total		less than 1	CFU/100mL	1	
Verified E.coli		less than 1	CFU/100mL	1	
Sample ID Well 2				Sample #	2
Date/Time Sampled	2020-02-04	12:00 PM Matrix	UGW	Temperature on Receipt	4
Date/Time on Test	2020-02-05	12:55 PM			
<u>Analyses</u>		<u>Result</u>	<u>Units</u>	RDL	
Coliforms, Total		less than 1	CFU/100mL	1	

## **Glossary of Terms**

Verified E.coli

Less than 1	Less than the Reportable Detection Limit, except under circumstances where the detection limit is higher due to interferences, insufficient sample volume, or dilutions.
APHA	American Pubic Health Association
CFU/100mL	Colony Forming Units per 100 milliliters
Matrix	SW = Surface water, TW = Treated water, DW= Distribution water, UGW = Untreated Ground water, RW = Raw water
RDL	Reportable Detection Limit

CFU/100mL

1

less than 1

## References