

Report# 7810

Filename 250305BFW.pdf

4240 Passmore Upper Road, Winlaw BC, V0G2J0 250-226-7339 test@passmorelaboratory.ca passmorelaboratory.ca

Client Beaver Falls Waterworks

Attention Wendy Allen

CERTIFICATE OF ANALYSIS

AnalysesMethod DescriptionReferenceTotal ColiformsMembrane Filtration on LES Endo mediumAPHA 9222BE. coliMF Partition on NA-MUG mediumAPHA 9222I

Tests were performed in accordance with methods outlined in the "Standard Methods for the Examination of Water and Wastewater", 23rd Edition, 2017 published by the American Public Health Association.

Passmore Laboratory Ltd. complies with methods and certification through the Province of British Columbia Enhanced Water Quality Assurance (EWQA) Program and the Clinical Microbiology Proficiency Testing (CMPT) Program. Other analytical results on this report not listed above are not within the scope of the EWQA. Passmore Laboratory assumes no responsibility for any loss or damage resulting from error or omission in the conduct of testing. Liability is limited to the cost of the analysis.

Processed by: Mechelle Babic

Mechelle Babic, Lab Manager

Please call or Email for with any questions, feedback, or more information

March 7, 2025 Page 1 of 2



Report# 7810

Filename 250305BFW.pdf

ΑN	ΙΔΙ	VT	$\Gamma \cap \Delta$.I E	2 F	เเว	ΙТ	7
\neg ıv	ותו	_		۱L I	۱L.	JU		

Sample ID Well 2				Sample # 1
Date/Time Sampled	2025-03-04	2:00 PM Matrix	UGW	Temperature on Receipt 7
Date/Time on Test	2025-03-05	2:20 PM		
<u>Analyses</u>		<u>Result</u>	<u>Units</u>	RDL
Coliforms, Total		less than 1	CFU/100mL	1
Verified E.coli		less than 1	CFU/100mL	1

Sample ID Yard Hydrant PH1 Sample					
Date/Time Sampled	2025-03-04	2:00 PM Matrix	UGW	Temperature on Receipt	6
Date/Time on Test	2025-03-05	2:25 PM			
<u>Analyses</u>		<u>Result</u>	<u>Units</u>	RDL	
Coliforms, Total		less than 1	CFU/100mL	1	
Verified E.coli		less than 1	CFU/100mL	1	

Glossary of Terms

Less than 1 Less than the Reportable Detection Limit, except under circumstances where the detection limit is higher due to

interferences, insufficient sample volume, or dilutions.

APHA American Public Health Association
CFU/100mL Colony Forming Units per 100 milliliters

Matrix SW = Surface water, TW = Treated water, DW = Distribution water, UGW = Untreated Ground water, RW = Raw water

RDL Reportable Detection Limit

References

March 7, 2025 Page 2 of 2