

ANALYTICAL RESULTS

Sample ID	1041 Christie Rd.			Sample #	1	
Date/Time Sampled	2024-10-08	4:00 PM	Matrix	UGW	Temperature on Receipt	12

Date/Time on Test 2024-10-09 11:25 AM

<u>Analyses</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>
Coliforms, Total	5	CFU/100mL	1
Verified E.coli	less than 1	CFU/100mL	1

Comments The sample does not meet drinking water guidelines for the Total Coliform Test

Glossary of Terms

Less than 1	Less than the Reportable Detection Limit, except under circumstances where the detection limit is higher due to interferences, insufficient sample volume, or dilutions.
APHA	American Public Health Association
CFU/100mL	Colony Forming Units per 100 milliliters
Matrix	SW = Surface water, TW = Treated water, DW = Distribution water, UGW = Untreated Ground water, RW = Raw water
RDL	Reportable Detection Limit

References